



# ECMPS Client Tool

Version 1.\* 2024 Q1

United States Environmental Protection Agency (EPA)  
Emissions Collection and Monitoring Plan System (ECMPS) Feedback

January 21, 2025 03:22 PM

Re: Newman Power Station (3456) - SC-7

Dear Certifying Official:

Thank you for submitting your Quarterly Emissions Report using the U. S. EPA`s Emissions Collection and Monitoring Plan System (ECMPS) software. This ECMPS Feedback report provides you with a detailed submission receipt, a summary of the evaluations performed on your submission, and guidance on any follow-up actions needed if any errors were found. EPA has also received a copy of this Feedback Report as part of your submission.

## SUBMISSION STATUS

The EPA has received your Quarterly Emissions Report for the Facility and Monitoring Location(s) listed in Table 1 below. The Table also provides confirmation of EPA`s receipt (Date, Time, etc.) of your submission. Prior to submission ECMPS evaluated your emissions report and assigned an overall "Feedback Status Level" to it, based on the results (see Table 1). This Feedback Report also contains Table 2, which displays EPA-Accepted Cumulative Values for emissions and other parameters. Finally, a summary of ECMPS`s Evaluation Results is included.

**Table 1: Submission Receipt and Feedback Status Level Information**

Report Received for Facility ID (ORIS Code):	3456
Facility Name:	Newman Power Station
State:	TX
Monitoring Locations:	SC-7
Submission Type:	EM for 2024 QTR 4
Feedback Status Level:	Informational Message
Submission Date/Time:	01/21/2025 3:22:27 PM
Submitter User ID:	igalindo
Submission ID:	1736273
Resubmission Required:	No
EPA Analyst:	Charles Frushour; (202) 343-9847; frushour.charles@epa.gov

## EXPLANATION OF YOUR FEEDBACK STATUS LEVEL LISTED IN TABLE 1

The EPA has accepted your Emissions data submission. ECMPS detected no errors in your data based on the checks performed; however, the Evaluation Results at the end of this Feedback Report contain one or more Informational Messages. If any of the Informational Messages indicates a reporting problem, the EPA strongly encourages you to correct the problem(s) and resubmit the data. NOTE: the ECMPS submission access window for this Emissions report has been closed. If you need to resubmit this data, please see the DATA RESUBMISSION guidance, below.

## OTHER INFORMATION AND BULLETINS FROM EPA

**QUESTIONS:** Please contact your EPA Analyst listed in Table 1 with any questions regarding this submission and the evaluation results. If you need assistance with correcting problems in the Emissions data for this facility, please send an e-mail to ECMPS Technical Support at: [ecmps-support@camdsupport.com](mailto:ecmps-support@camdsupport.com).

**DATA RESUBMISSION:** If you need to resubmit emissions data, including for previous calendar quarters, please complete the ECMPS Data Resubmission Request Form located at: [https://ecmps.camdsupport.com/help\\_resubmit\\_form.shtml](https://ecmps.camdsupport.com/help_resubmit_form.shtml). Please provide detailed documentation of the reasons for the resubmission. Support staff will review your request and notify you via e-mail when the necessary database access window has been granted for your resubmission.

**ECMPS Data Reporting Instructions:** for detailed information about reporting Monitoring Plan, QA/Certification Test, and Emissions data, please see the ECMPS Reporting Instructions on the EPA`s website at: <https://www.epa.gov/power-sector/ecmps-reporting-instructions>.

If you have any questions regarding this correspondence, please feel free to contact your EPA Analyst listed in Table 1 as soon as possible. Thank you for your attention to this matter.

**Table 2: Cumulative Data Summary -- EPA-Accepted Values**

Unit/Stack/Pipe ID: SC-7

	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Ozone Season	Year-to-Date
Number of Operating Hours		1,674	2,067	1,064	3,306	4,805
Operating Time (hrs)		1,655.69	2,060.91	1,050.85	3,283.17	4,767.45
SO2 Mass (tons)		0.8	1.1	0.5		2.4
CO2 Mass (tons)		152,352.8	219,958.5	104,936.1		477,247.4
Heat Input (mmBtu)		2,563,640	3,701,210	1,765,759	5,483,403	8,030,609
NOx Emission Rate (lb/mmBtu)		0.014	0.011	0.012		0.012
NOx Mass (tons)		16.9	20.3	10.0	30.8	47.2

EVALUATION RESULTS

Test Data

Unit/Stack/ Pipe	Test Type	Test Date/Hour	Sys / Comp ID	Sys / Comp Type / Scale	Severity	Check Code	Result Message
SC-7	DAYCAL	10/15/2024 09:52	7NO	NOX/H	INFORM	DAYCAL-2-A	The TestResultCode indicates that the daily calibration test for Location SC-7, Component 7NO and Type NOX at 10/15/2024 9:52:00 AM was aborted. If the test was aborted for a reason not related to monitor performance, you should not report the test.
				NOX/L	INFORM	DAYCAL-2-A	The TestResultCode indicates that the daily calibration test for Location SC-7, Component 7NO and Type NOX at 10/15/2024 9:52:00 AM was aborted. If the test was aborted for a reason not related to monitor performance, you should not report the test.
			7O2	O2/H	INFORM	DAYCAL-2-A	The TestResultCode indicates that the daily calibration test for Location SC-7, Component 7O2 and Type O2 at 10/15/2024 9:52:00 AM was aborted. If the test was aborted for a reason not related to monitor performance, you should not report the test.